



#### NOTES:

1. This is an above ground installation. Drawing depicts installation in a berm.
2. This is to be a private facility, governed by *UPC* and *Oregon Dept. of Human Services*, as applicable.
3. Device is to be supported by substantial material, resistant to rust and decay. Supports are to be installed to prevent undue stress or strain to the device and its service piping.



City Of Beaverton

#### ENGINEERING DEPARTMENT

UTILITIES ENGINEER  
David A. Winship, P.E.

DATE  
6 - 10 - 04

#### PRIVATE 1" REDUCED PRESSURE BACKFLOW PREVENTER

DRAWN BY  
CDH - WD

DRAWING NO.  
660